

## Condensafe+ Acid Neutraliser Refill

### Condensate Neutraliser for Domestic Condensing Boilers



#### Instructions for refilling




1 Unscrew cap and remove used neutraliser from the Condensafe+ unit.



2 Remove lid from refill pack tube. DO NOT take the neutraliser bag out of the tube.



3 Place the refill tube directly into the unit, the neutraliser bag should slide easily into place.



4 Ensure the refill is correctly seated inside the unit and does not block the outlet pipe.

5 Replace cap, ensuring it is sealed, but do not over tighten.

#### Refilling without cardboard tube



a If the neutraliser bag is misshaped and will not easily slide into the unit, use the following instructions.



b Reshape by squeezing contents to one end and place the thinner end into the unit.



c Knead the refill into place.



d The refill will slide into place. Finally follow steps 4 and 5 then wash hands.

#### IMPORTANT

To maintain optimum performance of the unit, it is recommended to replace the Condensafe+ acid neutralising media during each annual boiler service.

#### Disposal of the old acid neutraliser bag

Used neutraliser can be safely discarded with household waste.